



REDUCED PRESSURE BACKFLOW DEVICE

- NOTES:**
1. DEVICE MUST BE SET PLUMB INSIDE ENCLOSURE.
 2. DEVICES PLACED INSIDE OF BUILDING MUST PROVIDE A MINIMUM OF 24 INCHES CLEARANCE ON TEST COCK SIDE OF DEVICE AND AIR GAPPED DRAIN TO SANITARY SEWER.
 3. DEVICES LARGER THAN 2 INCHES MUST CONFORM TO OREGON HEALTH DIVISION INSTALLATION SPECIFICATIONS.
 4. ABOVE GROUND ENCLOSURE MUST HAVE A BORE-SIGHTED DRAIN TO DAYLIGHT AND ABILITY TO ACCESS TEST COCK SIDE OF DEVICE.

<p>NOTE: All material and workmanship shall be in accordance with the current Oregon Standard Specifications</p>	
<p style="text-align: center;">OREGON STANDARD DRAWINGS CITY OF HOOD RIVER REDUCED PRESSURE BACKFLOW DEVICE</p>	<p style="text-align: center;">2002</p>
<p>REVISIONS</p>	<p>DATE</p>
<p>12-02</p>	<p>City of Hood River Modifications</p>

The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user and should not be used without consulting a Registered Professional Engineer.